BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

VAN AMBATIELOS
VICE-PRESIDENT

VICTOR H. CUEVAS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES

CALIFORNIA

ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

CETCO
2870 Forbs Ave
Hoffman Estates, IL 60192

Attn: Robert Cisneros
(847) 851-1819

RESEARCH REPORT: RR 25669
(CSI 07110)

Expires: June 1, 2010
Issued Date: June 1, 2009
Code: 2008 LABC

GENERAL APPROVAL - Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System for Wall and Slab Waterproofing.

DETAILS

1. The above product is approved for below-grade waterproofing as required by Chapter 14 of the Los Angeles Building Code. The product may be used in conjunction with Los Angeles City approved caulking materials at penetrations of the waterproofing membrane.

2. The application of the material shall be in accordance with the manufacturer's instructions. A copy of the instruction shall be available at each job site.

3. The product shall be in full contact with the wall and soil at all times

LADBS G-5 (Rev.6/08) AN EQUAL EMPLOYMENT OPPORTUNITY - AFFIRMATIVE ACTION EMPLOYER

DISCUSSION

The report is in compliance with 2008 Los Angeles Building Code.

The approval is based on tests.

Strataseal HR was tested with 129 psi Hydrostatic Resistance.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

YEUAN CHOU, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone - 213-202-9812
Fax - 213-202-9942

TV:elcm
RR25669/MSWord2003
R06/01/09
2H6/1402/1805.5.6